



Farmer  
Environmental  
Services, LLC

6 Mo. Surveillance  
9/15

**AHERA THREE YEAR REINSPECTION**

per ph. conv. w/ Eric Columbo on 9-8-15  
can just date + sign 6 mo walk-thru

LEA: Carbondale CHSD # 165

School: Carbondale New School

Address: 1302 E. Pleasant Hill Rd. Carbondale,  
IL 62902

Contact/Phone: Amanda Sheridan/618-457-4765

FES# 1308-467

Date of Re-Inspection: August 27, 2013

**C. SUMMARY OF FINDINGS**

(known or assumed asbestos containing materials located in the building)

Area ID	Description of Material	Location of Material	Quantity	Contains Asbestos (Yes / No / Assumed)	Comments:
<b>CARBONDALE NEW SCHOOL – MAIN BUILDING</b>					
01-001	DRYWALL – CEILINGS & WALLS (WHITE)	ROOMS 4-6, 9-16, 18-20, & 22	9, 852 SQ. FT.	NO 3 NAD	JOINT COMPOUND NOT SAMPLED OR ANALYZED. WILL ADD JOINT COMPOUND TO MANAGEMENT PLAN. THIS MATERIAL CAN BE LEFT OUT.
01-002	NOT USED				
01-003	LINOLEUM (GOLD PEBBLE)	ROOMS 5, 6, & 9	576 SQ. FT.	YES 1 ACM	LINOLEUM HAS BEEN REMOVED & REPLACED BY FLOOR TILE. CERAMIC TILE & ANOTHER LINOLEUM POSSIBLY COULD HAVE JUST BEEN COVERED UP.
01-004	12" X 12" FLOOR TILE (WHITE W/ BEIGE FLECK & WHITE W/ GREY FLECK)	ROOMS 11-12, & 19	454 SQ. FT.	ASSUMED (PLM WAS NAD)	RECOMMENDED TEM SAMPLE & ASSUMING MATERIAL IS ACM UNTIL TEM.
01-005	12" X 12" CEILING TILE UNIFORM HOLES (WHITE)	ROOM 15 (LUNCH ROOM CLOSET)	49 SQ. FT.	NO 3 NAD	CEILING TILE MASTIC ASSUMED (01-012)
01-006	12" X 12" FLOOR TILE (GREEN PEBBLE)	ROOM 17 (KITCHEN)	132 SQ. FT.	ASSUMED	
01-007	LINOLEUM ADHESIVE (UNKNOWN COLOR)	ROOMS 5, 6, & 9	576 SQ. FT.	ASSUMED	LINOLEUM REMOVED FROM ROOMS 5, 6, & 9 POSSIBLY JUST COVERED UP. ASSUMING THIS MASTIC REMAINS
01-008	FLOOR TILE ADHESIVE FOR 004 & 006 (UNKNOWN COLOR)	ROOMS 11, 12, 17, & 19	586 SQ. FT.	ASSUMED	
01-009	CARPET ADHESIVE (UNKNOWN COLOR)	ROOMS 9, 10, 11, 16, & 19	1, 462 SQ. FT.	ASSUMED	ORIGINAL MANAGEMENT PLAN CARPET REMOVED AT SOME TIME. MASTIC MAY STILL BE UNDER FLOOR TILE.
01-010	FIRE DOORS (UNKNOWN COLOR)	ALL DOORS	ALL DOORS	ASSUMED	
01-011	BASEBOARD ADHESIVE (UNKNOWN COLOR)	ROOMS 5 & 6	144 SQ. FT.	ASSUMED	COVE BASE REMOVED & REPLACED W/ DIFFERENT BASES. ASSUMED THIS MASTIC STILL REMAINS.
01-012	CEILING TILE ADHESIVE FOR 01-005 (UNKNOWN COLOR)	ROOM 15 (LUNCH ROOM CLOSET)	49 SQ. FT.	ASSUMED	



# AHERA THREE YEAR REINSPECTION

LEA: Carbondale CHSD # 165  
 School: Carbondale New School  
 Address: 1302 E. Pleasant Hill Rd. Carbondale, IL 62902  
 Contact/Phone: Amanda Sheridan/618-457-4765  
 FES# 1308-467  
 Date of Re-Inspection: August 27, 2013

Area ID	Description of Material	Location of Material	Quantity	Contains Asbestos (Yes / No / Assumed)	Comments:
MFA	12" X 12" FLOOR TILE (SALMON)	ROOM 16	160 SQ. FT.	ASSUMED	NEW MATERIAL
MFA-M	12" X 12" FLOOR TILE MASTIC (UNKNOWN COLOR)	ROOM 16	160 SQ. FT.	ASSUMED	NEW MATERIAL
MFB	12" X 12" FLOOR TILE (WHITE W/ GREY FLECK)	ROOMS 4, 7, 8, 9, & 10	680 SQ. FT.	ASSUMED	NEW MATERIAL
MFB-M	12" X 12" FLOOR TILE MASTIC (UNKNOWN COLOR)	ROOMS 4, 7, 8, 9, & 10	680 SQ. FT.	ASSUMED	NEW MATERIAL
MFC	SHEET FLOORING (WHITE)	ROOMS 5 & 6 ENTRIES	90 SQ. FT.	ASSUMED	NEW MATERIAL
MFC-M	SHEET FLOORING ADHESIVE (UNKNOWN COLOR)	ROOMS 5 & 6 ENTRIES	90 SQ. FT.	ASSUMED	NEW MATERIAL
MMA	CARPET ADHESIVE (UNKNOWN COLOR)	ROOMS 9 & 10	480 SQ. FT.	ASSUMED	NEW MATERIAL
MMB	12" X 12" CERAMIC TILE (LIGHT GREY)	ROOMS 5 & 6	360 SQ. FT.	ASSUMED	NEW MATERIAL
MMB-G	12" X 12" CERAMIC TILE GROUT (UNKNOWN COLOR)	ROOMS 5 & 6	360 SQ. FT.	ASSUMED	NEW MATERIAL
MMB-M	12" X 12" CERAMIC TILE MORTAR (UNKNOWN COLOR)	ROOMS 5 & 6	360 SQ. FT.	ASSUMED	NEW MATERIAL
MMC	6" COVE BASE (WHITE)	ROOMS 11 & 19	25 SQ. FT.	ASSUMED	NEW MATERIAL
MMC-M	6" COVE BASE ADHESIVE (UNKNOWN COLOR)	ROOMS 11 & 19	25 SQ. FT.	ASSUMED	NEW MATERIAL
MMD	4" COVE BASE (LIGHT GREY)	ROOMS 5 & 6 ENTRIES	18 SQ. FT.	ASSUMED	NEW MATERIAL
MMD-M	4" COVE BASE ADHESIVE (UNKNOWN COLOR)	ROOMS 5 & 6 ENTRIES	18 SQ. FT.	ASSUMED	NEW MATERIAL
MME	6" COVE BASE (LIGHT GREY)	ROOM 6	10 SQ. FT.	ASSUMED	NEW MATERIAL
MME-M	6" COVE BASE ADHESIVE (UNKNOWN COLOR)	ROOM 6	10 SQ. FT.	ASSUMED	NEW MATERIAL
MMF	4" COVE BASE (BLACK)	ROOMS 9 & 10	30 SQ. FT.	ASSUMED	NEW MATERIAL
MMF-M	4" COVE BASE ADHESIVE (UNKNOWN COLOR)	ROOMS 9 & 10	30 SQ. FT.	ASSUMED	NEW MATERIAL
MMG	CHALKBOARDS (GREEN/BLACK)	ROOMS 1 & 2	128 SQ. FT.	ASSUMED	NEW MATERIAL
MMG-M	CHALKBOARD ADHESIVE (UNKNOWN COLOR)	ROOMS 1 & 2	128 SQ. FT.	ASSUMED	NEW MATERIAL
MMH	INTERIOR WINDOW FRAME CAULK (GREY)	BASEMENT: ORIGINAL WINDOWS	8 SQ. FT.	ASSUMED	NEW MATERIAL
MMI	INTERIOR WINDOW FRAME CAULK (WHITE)	BASEMENT: REPLACEMENT VINYL WINDOWS	6 SQ. FT.	ASSUMED	NEW MATERIAL
MMJ	INTERIOR WINDOW FRAME CAULK (WHITE)	1 <sup>ST</sup> FLOOR WINDOWS	45 SQ. FT.	ASSUMED	NEW MATERIAL
MMK	INTERIOR DOOR FRAME CAULK (TAN)	ROOM SPACE DOORS	26 SQ. FT.	ASSUMED	NEW MATERIAL
MML	INTERIOR DOOR FRAME CAULK (TAN)	BUILDING ENTRY/EXIT DOORS	8 SQ. FT.	ASSUMED	NEW MATERIAL



# AHERA THREE YEAR REINSPECTION

LEA: Carbondale CHSD # 165  
 School: Carbondale New School  
 Address: 1302 E. Pleasant Hill Rd. Carbondale, IL 62902  
 Contact/Phone: Amanda Sheridan/618-457-4765  
 FES# 1308-467  
 Date of Re-Inspection: August 27, 2013

Area ID	Description of Material	Location of Material	Quantity	Contains Asbestos (Yes / No / Assumed)	Comments:
MXA	JOINT COMPOUND (WHITE)	ROOMS 1-16, 19, & 22	9, 832 SQ. FT.	ASSUMED	NEW MATERIAL
MMM	EXTERIOR WINDOW FRAME CAULK (GREY)	BASEMENT: ORIGINAL WINDOWS	8 SQ. FT.	ASSUMED	NESHAPS REGULATED MATERIAL
MMN	EXTERIOR WINDOW GLAZING (GREY)	BASEMENT: ORIGINAL WINDOWS	16 SQ. FT.	ASSUMED	NESHAPS REGULATED MATERIAL
MMO	EXTERIOR WINDOW FRAME CAULK (WHITE)	BASEMENT: REPLACEMENT VINYL WINDOWS	6 SQ. FT.	ASSUMED	NESHAPS REGULATED MATERIAL
MMP	EXTERIOR WINDOW FRAME CAULK (WHITE)	1 <sup>ST</sup> FLOOR WINDOWS	45 SQ. FT.	ASSUMED	NESHAPS REGULATED MATERIAL
MMQ	EXTERIOR WINDOW GLAZING (WHITE)	1 <sup>ST</sup> FLOOR WINDOWS	45 SQ. FT.	ASSUMED	NESHAPS REGULATED MATERIAL
MMR	EXTERIOR DOOR FRAME CAULK (GREY)	BUILDING ENTRY/EXIT DOORS	8 SQ. FT.	ASSUMED	NESHAPS REGULATED MATERIAL
MMS	ROOFING MATERIALS (GREY SHINGLE W/ BLACK)	ROOF	3, 600 SQ. FT.	ASSUMED	NESHAPS REGULATED MATERIAL
<b>CARBONDALE NEW SCHOOL - GAZEBO PLAYGROUND</b>					
MMA	ROOFING MATERIALS (GREY SHINGLE BLACK)	GAZEBO ROOF	36 SQ. FT.	ASSUMED	NESHAPS REGULATED MATERIAL
<b>CARBONDALE NEW SCHOOL – PORTABLE CLASSROOM BUILDING</b>					
SCA	CEILING TEXTURE MATERIAL FLUFFY/"POPCORN" (WHITE)	CEILINGS	1, 176 SQ. FT.	ASSUMED	NEW MATERIAL
MFA	12" X 12" FLOOR TILE (LIGHT BLUE)	CLASSROOMS	410 SQ. FT.	ASSUMED	NEW MATERIAL
MFA-M	12" X 12" FLOOR TILE MASTIC (UNKNOWN COLOR)	CLASSROOMS	410 SQ. FT.	ASSUMED	NEW MATERIAL
MFB	12" X 12" FLOOR TILE (MEDIUM BLUE)	CLASSROOMS	24 SQ. FT.	ASSUMED	NEW MATERIAL
MFB-M	12" X 12" FLOOR TILE MASTIC (UNKNOWN COLOR)	CLASSROOMS	24 SQ. FT.	ASSUMED	NEW MATERIAL
MFC	12" X 12" FLOOR TILE (WHITE W/ BLUE FLECK)	CLASSROOMS	640 SQ. FT.	ASSUMED	NEW MATERIAL
MFC-M	12" X 12" FLOOR TILE MASTIC (UNKNOWN COLOR)	CLASSROOMS	640 SQ. FT.	ASSUMED	NEW MATERIAL
MFD	12" X 12" FLOOR TILE (TAN)	LOBBY & RESTROOMS	156 SQ. FT.	ASSUMED	NEW MATERIAL
MFD-M	12" X 12" FLOOR TILE MASTIC (UNKNOWN COLOR)	LOBBY & RESTROOMS	156 SQ. FT.	ASSUMED	NEW MATERIAL
MMA	4" COVE BASE (DARK BROWN)	ALL ROOMS	70 SQ. FT.	ASSUMED	NEW MATERIAL
MMA-M	4" COVE BASE MASTIC (UNKNOWN COLOR)	ALL ROOMS	70 SQ. FT.	ASSUMED	NEW MATERIAL



# AHERA THREE YEAR REINSPECTION

LEA: Carbondale CHSD # 165  
 School: Carbondale New School  
 Address: 1302 E. Pleasant Hill Rd. Carbondale, IL 62902  
 Contact/Phone: Amanda Sheridan/618-457-4765  
 FES# 1308-467  
 Date of Re-Inspection: August 27, 2013

Area ID	Description of Material	Location of Material	Quantity	Contains Asbestos (Yes / No / Assumed)	Comments:
MMB	INTERIOR WINDOW FRAME CAULK (WHITE)	WINDOWS	8 SQ. FT.	ASSUMED	NEW MATERIAL
MMC	INTERIOR DOOR FRAME CAULK (WHITE)	ROOM SPACE DOORS	6 SQ. FT.	ASSUMED	NEW MATERIAL
MMD	INTERIOR DOOR FRAME CAULK (WHITE)	BUILDING ENTRY/EXIT DOORS	4 SQ. FT.	ASSUMED	NEW MATERIAL
MWA	DRYWALL	ALL WALLS & CEILINGS	3, 500 SQ. FT.	ASSUMED	NEW MATERIAL
MXA	JOINT COMPOUND	ALL WALLS & CEILINGS	3, 500 SQ. FT.	ASSUMED	NEW MATERIAL
MME	EXTERIOR WINDOW FRAME CAULK (WHITE)	WINDOWS	8 SQ. FT.	ASSUMED	NESHAPS REGULATED MATERIAL
MMF	EXTERIOR WINDOW FRAME GLAZING (WHITE)	WINDOWS	12 SQ. FT.	ASSUMED	NESHAPS REGULATED MATERIAL
MMG	EXTERIOR DOOR FRAME CAULK (WHITE)	BUILDING ENTRY/EXIT DOORS	4 SQ. FT.	ASSUMED	NESHAPS REGULATED MATERIAL
MMH	ROOFING MATERIALS (BLACK)	ROOF	1, 200 SQ. FT.	ASSUMED	NESHAPS REGULATED MATERIAL