



One North Spanish Street / Cape Girardeau Missouri 63701

573-651-3329 / 800-659-3329 Fax: 573-651-3496

E-mail: meadenv@mydci.com

June 4, 2001

Carbondale New School Attn: Ms Linda Rohling RR1 Pleasant Hill Road Carbondale, IL 62901

Re: Three-year reinspection of asbestos containing materials and assumed asbestos containing materials

Dear Ms. Rohling:

On May 30, 2001, David J. Roth conducted the required three-year AHERA reinspection of Carbondale New School. The inspection included all *friable and non-friable*, assumed and tested, ACM in all buildings of the school. Licenses for the inspector and management planner are attached.

The following items are noted:

- 1. No homogeneous areas of friable, assumed or known, asbestos containing materials were identified in this school.
- 2. The homogeneous areas of **non-friable**, assumed or known, asbestos containing materials have not become more friable since the 1998 reinspection.
- 3. All materials listed as asbestos containing or assumed to contain asbestos shall remain in the Operations and Maintenance Program until removed.

If you have any questions please call me at 1.800.659.3329. Thank you.

Sincerely,

MEAD Environmental Associates, Inc.

David J. Roth

Inspector/Management Planner

THREE-YEAR ASBESTOS REINSPECTION DOCUMENTATION

On May	<i>30, 2001</i> , I,	DAUID J. ROTH,
conducted the 3-	year AHERA reinspection	DAUID J. ROTH on of CARbondale New School,
		Project ID #
	•	BIR License # <u>Il - 100 - 0060</u>
Non-friable mat	terials have / have not	become friable since the last reinspection.
Friable materia	ls have / have not become	ome friable / more friable since the last reinspection.
		have become friable / more friable since the last the attached inspection form for hazard assessment.
ID#	MATERIAL	LOCATION OF DAMAGE
	•	
	SIGNATU	RE_ Chan (Soll
. •		
MEAD Enviror	nmental Associates, Inc.	1.800.659.3329

LEA Name: CARBONDALE New School

Homogeneous Area Inventory for Job # 447 Sampling date: 6 - 16 - 89
Use red Ink to complete this form.

	Remova Priority	# 00-000	Material	Size	SM/M 131	IM NAE) ACM	ASSM'D	l ² rin	bility IT no	Damage yes no
		01-001	Drywall Same AS 003	9832	mn	X			-	K.	4
	4	01-004	FT	576 454	mm	X	X		-	X	4
dr	4	01-005	FT	<u>49</u> 	mm	\times	X		6X	X	7
6-1	6	01-007	Linoleum Adhesive FT Adhesive Carpet Adhesive	586	mm mm						X
7-6	6	01-010	Fire Doors Booksond Adhesive	1.462 Au Doors	mm mm						X
	6	01-012	CT Adhesive	49	mm						X
									\parallel	1	
						_				 	
										E	
-											
. -											
-											
-											
13-ma										 	

SM - SURFACING MATERIAL

MM - MISCELIANEOUS MATERIAL

TSI - THERMAL SYSTEM INSULATION

CT - CEILING TILE

Fr - FLOOR TILE

NAD - NO ASITESTOS DELECTED .

ACM - ASBESTOS CONTAINING MATERIAL